

**State of California
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles**

**FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CHEVRON USA PRODUCTS COMPANY
NPDES NO. CAG674001
CI-8393**

PROJECT LOCATION

Montebello Terminal
601 South Vail Avenue
Montebello, CA 90640

FACILITY MAILING ADDRESS

P.O. Box 2292
Brea, CA 92822
Contact: Mr. Ron Wise

PROJECT DESCRIPTION

Chevron USA Products Company (herein after Chevron) proposes to perform hydrostatic testing of a new storage tank at located 601 South Vail Avenue in Montebello. The storage tank construction is proposed to begin in August 2002, and the hydrostatic testing will be conducted at the end of the construction project. The capacity of the tank is 2.1 million gallons. The hydrostatic test will be performed using municipal water from the California Water Service Company.

VOLUME AND DESCRIPTION OF DISCHARGE

Chevron proposes to discharge up to 2.1 million gallons of wastewater during the hydrostatic testing. If chlorine is present in the wastewater, sodium thiosulfate chemical injection system will be utilized to mitigate the chlorine prior to discharge. The wastewater will be discharged to the storm drain (Outfall No. 001) located on site (Latitude 34° 00' 17", Longitude 118° 7' 28"). The discharge will flow directly to Rio Hondo River (Los Angeles River Watershed), a water of the United States. See Figure 1 for site location map.

FREQUENCY OF DISCHARGE

The discharge will last for approximately one week. The maximum discharge flow rate will not exceed one million gallons per day. The discharge is proposed to begin in late September 2002.

REUSE OF WATER

Use for dust control was considered as a viable reuse alternative at the site. However, it is not feasible because of the high flow rate and the limited area requiring dust control. Therefore, the wastewater will be discharged to the Rio Hondo River.